

TECHTOP
Shanghai Top Motor Co., Ltd
NO.303 Kangliu Road Kangqiao Industry Zone
Pudong, Shanghai, 201315, P.R. China

Deres ref. Henry Larsen Af den 08-04-2013

Telefon 2688 7503

Vores ref. PL

Dato 08-04-2013

Fax 8870 8090

Subject: ATEX Zone 2 certification on electrical motor series

By this letter TÜV Nord, Notified Body No. 0044, can confirm that the below mentioned system has been assessed in accordance with the requirements of the ATEX Directive – 94/9/EC, in order to issue “Certificate of Conformity” for use in Category 3.

Electrical Motor
Types: T1A, T1C, MS, T2A, T2C and MS2

Marked:



II 3 G Ex nA IIC T4 Gc
II 3 D Ex tc IIIC T125 °C Dc

The units are designed for use in Zone 2 area.


Evaluation was performed in accordance with the standards: EN 60079-0:2009, EN 60079-15:2010 and EN 60079-31:2009. It can be concluded that the motor types listed above meets relevant requirements for Category 3 equipment (Zone 2) to Directive 94/9/EC when installed in accordance with Techttop’s installation requirements. The final ATEX “Certificate of Conformity” with the TÜV Certificate number TÜV 12 ATEX 111822 X will be issued when the final paperwork is finalized.

Further to the above, I can confirm that the Final review has been delayed due to several internal issues and severe workload.

We are in continuous contact with the certification office in order to speed up the process and indications are showing that the project will be finished soon.

We can confirm that the delay is solely based on internal administrative issues.

Best regards,



Peter T. Lauritzen
TÜV Nord Danmark